

**PEDOMAN OPERASI STANDAR (SOG)  
STANDARD OPERATING GUIDELINE**

**Mining Safety Division  
Emergency Preparedness and Response**

**SOG-4.09-EPR- 705**

No. Standar Standard No.	STD-4.09-PTFI-2020
Tanggal Pembuatan Date Created	20 April 2022 April 20, 2022
Jumlah Halaman Number of pages.	# 5
Menggantikan Superseded	N/A
No. Revisi Revision No.	#1
Tanggal Revisi. Revisi date.	25 April 2025 April 25, 2025
Tanggal Efektif Effective Date	25 Mei 2025 May 25 <sup>th</sup> , 2025

Judul/Title:

**EMERGENCY EGRESS DRILL**


**Pengesahan:  
Approval:**

*General Supt. Emergency Preparedness and Response (EP&R)*




**Hanny Runtuwene**

*General Supt. Fire System Maintenance & Engineering (FSME)*



**Mark Jenkins**

*Head Of Campus, MZS Tembagapura*




**James Crawford**

*Head of Campus, MZS Kuala Kencana*



**Mark Jenkins**

*Head Of Campus, YPJ Tembagapura*



**Bayu Cahyo Widyatmoko**

*Head of Campus, YPJ Kuala Kencana*



**Abidin Nur Rahmat**

## 1. TUJUAN

Dokumen ini dibuat guna menetapkan pedoman berdasarkan Standar *National Fire Protection Association (NFPA) 101 Life Safety Code* Edisi 2015 untuk diterapkan pada saat melakukan *Emergency Egress Drill* baik di Sekolah Yayasan Pendidikan Jayawijaya (YPJ) dan/atau Sekolah *Mount Zaagkham (MZS)* di Dataran Tinggi dan Dataran Rendah.

## 2. CAKUPAN

Sebagai upaya untuk membiasakan penghuni gedung sekolah dengan prosedur latihan, dan untuk menetapkan penggunaan sarana jalan keluar darurat sebagai rutinitas, Penghubung (Liaison) Sekolah YPJ dan/atau MZS bekerja sama dengan *Emergency Preparedness & Response (EP&R)* untuk menetapkan *Emergency Egress Drill* yang berbasis sasaran. *Emergency Egress Drill* harus dilakukan sebagai berikut:

- a) Jumlah *Emergency Egress Drill* yang disyaratkan untuk dilakukan per tahun adalah sebanyak delapan (8). Masing-masing dilakukan sekali per bulan. Lihat Lampiran A untuk Jadwal *Emergency Egress Drill*.
- b) Semua penghuni bangunan harus berpartisipasi pada latihan ini.

## 3. PROSES PRA DRILL

Sebelum *Emergency Egress Drill* dimulai, proses di bawah ini harus dilakukan:

- a) Tergantung di mana latihan akan dilakukan, Penghubung (*Liaison*) Sekolah (lihat Bagian VI untuk Nara Hubung) mengirim email kepada *EP&R General Superintendent* dan/atau orang yang ditunjuknya sehubungan dengan permintaan izin untuk menggunakan nomor keadaan darurat 546-7777 selama *Emergency Egress Drill*, paling tidak satu minggu sebelum latihan.
- b) Penghubung (*Liaison*) Sekolah juga mengirimkan email ke *General Superintendent Fire System Maintenance & Engineering (FSME)* dan/atau yang ditunjuknya sehubungan dengan permintaan perwakilan FSME untuk hadir di sekolah selama latihan. Perwakilan FSME yang hadir di sekolah tersebut ditugaskan untuk melakukan *reset panel kontrol alarm* kebakaran, setelah latihan selesai.

## 1. PURPOSE

This document was developed to establish guidelines set forth from the *National Fire Protection Association (NFPA) 101 Life Safety Code 2015 Edition*, to be implemented in the event of an *Emergency Egress Drill* both at *Yayasan Pendidikan Jayawijaya (YPJ) School* and *Mount Zaagkham School (MZS)* in the Highlands and Lowlands.

## 2. SCOPE

In an effort to familiarize the school building occupants with the drill procedure, and to establish conduct of emergency egress as a matter of routine, the YPJ School and/or MZS *Liaison(s)* works with *Emergency Preparedness & Response (EP&R)* to establish the required objective-driven *Emergency Egress Drill(s)*. *Emergency Egress Drills* shall be conducted as follows:

- a) The required number of *Emergency Egress Drills* shall be conducted are eight (8) times per year. They are to be conducted on a monthly basis. Refer to Appendix A for the *Emergency Egress Drill Schedule*.
- b) All occupants of the building shall participate in the drill.

## 3. PRE DRILL PROCESS

All-clear process shall occur according to the following process:

- a) Depending upon where the drill will be conducted, the *School Liaison* (see Section VI for *Point of Contacts*) to send an email correspondence to the *General Superintendent of EP&R* and/or his/her designee with regards to requesting permission to use 546-7777 emergency number during the *Emergency Egress Drill*, at least one week prior to the drill.
- b) The *School Liaison* to also send an email correspondence to the *General Superintendent of Fire System Maintenance & Engineering (FSME)* and/or his/her designee with regards to requesting for an *FSME representative* to be present at school during the drill. *FSME representative* present at the school is tasked with resetting the fire alarm control panel, once the drill has been completed.

- c) Perwakilan EP&R memastikan bahwa izin penggunaan nomor darurat 546-7777 telah diberikan oleh *General Superintendent EP&R* dan/atau yang ditunjuknya. Orang ini juga bertugas untuk *silence* panel kontrol alarm kebakaran dan memberikan pesan *all-clear* setelah latihan selesai.

#### 4. PELAKSANAAN DRILL

Proses pelaksanaan latihan harus dilakukan mengikuti proses di bawah ini:

- Tergantung di mana latihan akan dilakukan, Penghubung (*Liaison*) Sekolah akan secara resmi memberi tahu PTFI *Command Center* melalui nomor telepon 546-3100 satu jam sebelum latihan.
- Sekolah harus menunjuk seseorang untuk membunyikan alarm untuk memulai proses latihan.
- Sekolah harus menunjuk seseorang untuk menelepon nomor keadaan darurat 546-7777 dan mengatakan "*Drill, Drill, Drill*" dan menjawab semua pertanyaan terkait dari *Call Taker*.
- Semua penghuni gedung sekolah harus meninggalkan bangunan menuju "Titik Kumpul Evakuasi" untuk dihitung jumlahnya.

#### 5. PROSES ALL CLEAR

Proses *all-clear* latihan harus dilakukan mengikuti proses di bawah ini:

- Perwakilan EP&R hadir di sekolah untuk mematikan (*silence*) panel kontrol alarm kebakaran dan menyampaikan kepada perwakilan FSME untuk melakukan *reset* panel kontrol alarm kebakaran, setelah telah dimatikan.
- Perwakilan EP&R memberikan pesan *all-clear* kepada Penghubung (*Liaison*) Sekolah untuk melanjutkan operasi sekolah mereka.
- Setelah *Emergency Egress Drill* telah selesai, Penghubung (*Liaison*) sekolah menghubungi PTFI *Command Center* di nomor 546-3100 untuk menyampaikan bahwa *Emergency Egress Drill* telah selesai.

#### 6. NARA HUBUNG

Di bawah ini adalah nara hubung/penghubung untuk *Emergency Egress Drill* di sekolah.

DEPARTEMEN DEPARTMENTS	PENGHUBUNG LIAISON(S)	ORANG YANG DITUNJUK DESIGNEE(S)
<i>Emergency Preparedness &amp; Response (EP&amp;R).</i>	Randy Julius.	Frits Worabay, Frendy Tular, Wingston Kaemor.
YPJ School, Kuala Kencana.	Yoppy Ariansyah.	Pantun Hutabarat.
YPJ School, Tembagapura.	Bayu Widyatmoko.	N/A.

- c) EP&R representative to ensure that the permission to use 546-7777 emergency number has been given by the General Superintendent of EP&R and/or his/her designee. This person is also tasked with silencing the fire alarm control panel and give the *all-clear* message upon completion of the drill.

#### 4. DRILL CONDUCT

Drill conduct process shall occur according to the following process:

- Depending upon where the drill will be conducted, the School Liaison to officially notify PTFI *Command Center* via 546-3100 one hour prior to the drill conduct.
- The school shall designate a person to pull the alarm to initiate the drill process.
- The school shall designate a person to call 546-7777 emergency number and say "*Drill, Drill, Drill*" and answer all pertinent questions asked by the *Call Taker*.
- All of the school building occupants shall proceed to "*Evacuation Assembly Point*" to be accounted for.

#### 5. ALL CLEAR PROCESS

*All-clear* process shall occur according to the following process:

- EP&R representative present at school to silence the fire alarm control panel and to advise FSME representative to reset the fire alarm control panel, once being silenced.
- EP&R representative to give the *all-clear* message to the School Liaison(s) to resume their school operations.
- Upon completion of the *Emergency Egress Drill*, the school liaison to call the PTFI *Command Center* at 546-3100 to advise that the *Emergency Egress Drill* has been completed.

#### 6. POINT OF CONTACTS

The following are points of contacts/*liaisons* for the school *Emergency Egress Drill*:

Mount Zaagkham School, Kuala Kencana.	Nona Dekana.	N/A.
Mount Zaagkham School, Tembagapura.	Gery Hulagrocki.	N/A.

## 7. REFERENSI

### REFERENCE

- 7.1 NFPA 101 Life Safety Code (LSC) 2021 Edition, Chapter 15.7.2 on Emergency Egress Drills.
- 7.2 STD-4.09-PTFI-2022 Emergency Management.
- 7.3 KEPMEN 1827/2018.

## 8 RIWAYAT REKAM SOG

### SOG HISTORICAL RECORD

Tanggal Revisi Date of Revision	Dibuat / Direvisi oleh Written / Revised by	Deskripsi Revisi Revision Description
29/4/2025	EP&R	Review of the year effective date.
1/5/2025	FSME	Menandatangani Persetujuan: Sign Approval: Samuel Situmorang telah digantikan oleh Nurcahyo Prihatsono. Samuel Situmorang was replaced by Nurcahyo Prihatsono.

## 9 LAMPIRAN

### APPENDIX

- 9.1 Jadwal Emergency Egress Drill.  
Emergency Egress Drill.

*Jadwal Emergency Egress Drill.  
Emergency Egress Drill Schedule.*

# CALENDAR

January	February Egress Drill	March Egress Drill
April Egress Drill	May Egress Drill	June
July	August Egress Drill	September Egress Drill
October Egress Drill	November Egress Drill	December